



Certificate of Compliance

Solid Stream Nozzles

This certificate is issued for the following equipment:

Models NW500 Solid Stream Nozzles
500 gpm (1895 Lpm), 175 psi (12.1 bar) rated service pressure
3 in. (76 mm) water inlet connection

Models NW700 Solid Stream Nozzles
700 gpm (2650 Lpm), 175 psi (12.1 bar) rated service pressure
3 in. (76 mm) water inlet connection

Models NW1000 Solid Stream Nozzles
1000 gpm (3785 Lpm), 175 psi (12.1 bar) rated service pressure
4 in. (102 mm) water inlet connection

Manufactured by:

DH Fire Protect Pvt. Lt.
7K-98, MIDC, Ajanta Road
Jalgaon - 425003
India

FM Approvals confirms that the items have been found to comply with the following standard:

FM Approvals Standard 5511 (Draft Revision 3.3, October 28, 2004)

Project Identifier: 3020543

Date of Approval: January 19, 2005



An **FM** Global Enterprise™


Roger L. Allard, Assistant Vice President
FM Approvals - Hydraulics Group

February 24, 2005
Date