

CERTIFICATE OF COMPLIANCE

Certificate Number 20170821-EX5050
Report Reference EX5050-19961024
Issue Date 2017-AUGUST-21

Issued to: HD FIRE PROTECT PVT LTD
K-98, MIDC
AJANTA RD
JALGAON MH 425003 INDIA

**This is to certify that
representative samples of**

SPECIAL SYSTEM WATER CONTROL VALVES, DELUGE
TYPE

Deluge valves, Model A, 2, 3, 4, 6 and 8 in. size for vertical
installation only with working pressure not to exceed 175
psig.

Deluge valves skid mounted, Model DSK-AD and DSK-AW,
2, 3, 4, 6 and 8 in. size for vertical installation only with
working pressure not to exceed 175 psig.

Deluge valves skid mounted with pack, Model DPACK-AD
and DPACK-AW, 2, 3, 4, 6 and 8 in. size for vertical
installation only with working pressure not to exceed 175
psig


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 260 - Standard for Dry Pipe and Deluge Valves for Fire-
Protection Service

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

