

CERTIFICATE OF COMPLIANCE

Certificate Number EX16169
Report Reference EX16169-2013-02-28
Date 2022-November-14

Issued to: HD FIRE PROTECT PVT LTD
K-98, MIDC
AJANTA RD
JALGAON Maharashtra, 425003 IN

This is to certify that representative samples of FOAM MONITORS
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 162 UL Standard For Safety For Foam Equipment and Liquid Concentrates

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX16169
Report Reference EX16169-2013-02-28
Date 2022-November-14

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Foam monitors for application of firefighting foam solutions for models, types, inlet pressures and solution discharge flow

Monitor Model	Nozzle Model	Type	Nozzle Inlet Pressure, psi	Solution Flow, gpm
Varun 443	Varsha H4-500	B,C	100	500
Varun 443	Varsha H4-750	B,C	100	750
Varun 443	Varsha H4-750	B,C	100	1000
Varun 443	Varsha H4-V 500-750	B,C	100	500
			100	750
Varun 443	Varsha H4-V 750-1000	B,C	100	750
			100	1000
Varun 443	Varsha H4-V 500-1000	B,C	100	500
			100	1000
Varun 443	Varsha H4-V 500-750-1000	B,C	100	500
			100	750
			100	1000
Varun 443	Varsha H4-V 500-750-1000 with JRCP Model JP4	B,C	100	500
			100	750
			100	1000
Varun 643	Varsha HF4V 500-1000	B,C	100	500


 Deborah Jennings-Conner, VP Regulatory Services
 UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number EX16169
Report Reference EX16169-2013-02-28
Date 2022-November-14

			100	1000
Varun 643	Varsha HF4V 750-1000	B,C	100	750
			100	1000
Varun 643	Varsha HF4V 500-750	B,C	100	500
			100	750
Varun 643	Varsha HF4V 500-750-1000	B,C	100	500
			100	750
			100	1000
Varun 643	Varsha HF4VJ 500-1000 with JRCF Model JP4	B,C	100	500
			100	1000
Varun 643	Varsha HF4VJ 750-1000 with JRCF Model JP4)	B,C	100	750
			100	1000
Varun 643	Varsha HF4VJ 500-750 with JRCF Model JP4	B,C	100	500
			100	750
Varun 643	Varsha HF4VJ 500-750-1000 with JRCF Model JP4	B,C	100	500
			100	750
			100	1000
Varun 643	Varsha HF50 1000	B,C	100	1000
Varun 643	Varsha HF50 1250	B,C	100	1250
Varun 643	Varsha H6 1500	B,C	100	1500
Varun 643	Varsha H6 2000	B,C	100	2000

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC




Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number EX16169
Report Reference EX16169-2013-02-28
Date 2022-November-14

Monitor Model	Nozzle Model	Type	Nozzle Inlet	Solution
			Pressure, psi	Flow, gpm
Varun 643	Varsha H6-V 1000-1500	B,C	100	1000
			100	1500
Varun 643	Varsha H6-V 1000-2000	B,C	100	1000
			100	2000
Varun 643	Varsha H6-V 1500-2000	B,C	100	1500
			100	2000
Varun 643	Varsha H6-V 1000-1500-2000	B,C	100	1000
			100	1500
			100	2000
Varun 643	Varsha H6-VJ 1000 with JRCP Model JP6	B,C	100	1000
Varun 643	Varsha H6-VJ 1500 with JRCP Model JP6	B,C	100	1500
Varun 643	Varsha H6-VJ 2000 with JRCP Model JP6	B,C	100	2000
Varun 643	Varsha H6-VJ 1000-1500 with JRCP Model JP6	B,C	100	1000
			100	1500
Varun 643	Varsha H6-VJ 1000-2000 with JRCP Model JP6	B,C	100	1000
			100	2000
Varun 643	Varsha H6-VJ 1500-2000 with JRCP Model JP6	B,C	100	1500
			100	2000
Varun 643		B,C	100	1000


 Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number EX16169
Report Reference EX16169-2013-02-28
Date 2022-November-14

	Varsha H6-VJ 1000-1500-2000 with JRCP Model JP6		100	1500
			100	2000
Varun 643	Varsha HF6V 1000-2000	B,C	100	1000
			100	2000
Varun 643	Varsha HF6V 1500-2000	B,C	100	1500
			100	2000
Varun 643	Varsha HF6V 1000-1500	B,C	100	1000
			100	1500
Varun 643	Varsha HF6V 1000-1500-2000	B,C	100	1000
			100	1500
			100	2000
Varun 643	Varsha HF6VJ 1000-2000 with JRCP Model JP6	B,C	100	1000
			100	2000
Varun 643	Varsha HF6VJ 1500-2000 with JRCP Model JP6	B,C	100	1500
			100	2000
Varun 643	Varsha HF6VJ 1000-1500 with JRCP Model JP6	B,C	100	1000
			100	1500
Varun 643	Varsha HF6VJ 1000-1500-2000 with JRCP Model JP6	B,C	100	1000
			100	1500
			100	2000
VAJRA 331	VARSHA HF40U-500	B,C	100	500
VAJRA 331	VARSHA HF40U-750	B,C	100	750
VAJRA 331	VARSHA 40U-500	B,D	100	500


 Deborah Jennings-Conner, VP Regulatory Services
 UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number EX16169
Report Reference EX16169-2013-02-28
Date 2022-November-14

Monitor Model	Nozzle Model	Type	Nozzle Inlet Pressure, psi	Solution Flow, gpm
VAJRA 331	VARSHA 40U-750	B,D	100	750
VAJRA 331	VARSHA 40U-1000	B,D	100	1000
VAJRA 331-S	VARSHA HF40U-500	A,C	100	500
VAJRA 331-S	VARSHA HF40U-750	A,C	100	750
VAJRA 331-S	VARSHA 40U-500	A,D	100	500
VAJRA 331-S	VARSHA 40U-750	A,D	100	750
VAJRA 331-S	VARSHA 40U-1000	A,D	100	1000

Deborah Jennings-Conner
Deborah Jennings-Conner, VP Regulatory Services

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>